

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF AUXIER WATER )	
COMPANY, INC. FOR A DEVIATION FROM )	CASE NO. 94-251
807 KAR 5:066, SECTION 15(2), )	
REGARDING METER TESTING )	

O R D E R

By letter received on June 16, 1994, Auxier Water Company, Inc. ("Auxier") requested a deviation from 807 KAR 5:066, Section 15(2). This regulation requires that any meter removed from service for any cause, be tested for accuracy as specified therein prior to being placed in service.

On September 23, 1994, Auxier filed another letter informing the Commission that it had purchased meter locks for its meters, and will lock the water meter instead of removing it whenever a customer moves. If the meter is not taken out of service, a deviation will not be necessary. The Commission will consider Auxier's letter as a motion to withdraw its application. Having considered Auxier's response, the Commission finds that good cause exists to grant the motion and dismiss this case.

IT IS HEREBY ORDERED that:


1. Auxier's motion is granted.
2. This case is dismissed without prejudice.

Done at Frankfort, Kentucky, this 13th day of October, 1994.

**PUBLIC SERVICE COMMISSION**

  
Chairman

  
Vice Chairman

  
Commissioner

**ATTEST:**

  
Executive Director